

PAVUS, a.s.

Notified Body No. 1391 Prosecká 412/74, 190 00 Praha 9 - Prosek Authorization No. UNMZ/SPR/106/4000/18-7 from 20th November 2018

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1391-CPR-2020/0129/01

In compliance with the Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product:

Fire damper CFDM and CFDM-V

Intended use of the product in the building

Fire dampers are used to maintain fire compartments and protect means of escape in case of fire in heating, ventilation and air conditioning (HVAC) systems in buildings. All fire dampers close automatically in response to raised temperatures indicating fire.

placed on the market under the name or company name or trade mark of producer:

MANDIK, a.s.

Dobříšská 550, 267 24 Hostomice, Czech Republic, IČO 26718405

and produced in the manufacturing plant:

MANDÍK, a.s.

Dobříšská 550, 267 24 Hostomice, Czech Republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 15650:2010

under system 1 for the performance set out in this certificate are applied and that the factory production control carried out by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This Certificate was first issued on 8th June 2016 and remains valid until the harmonised standard, the construction product, the assessment and verification procedures for constancy of performance or the manufacturing conditions in the plant of manufacture are significantly modified or the notified product certification body amends or cancels the certificate.

This Certificate replaces and cancels Certificate of Constancy of Performance No. 1391-CPR-2020/0129 of 20th August 2020 issued by NB 1391.

Prague, 18th September 2020

Jaroslav Dufek

Managing Director PAVUS/a.s.

Notified Body No.1391

Technical parameters of the assessed product *)

External dimension of the element: min. \varnothing 100 mm – max. \varnothing 200 mm

Construction length:

64 mm - CFDM

114 mm - CFDM-V

Starting devices and drives:

fuse safety lock 72°C with closing spring

Material versions:

galvanized sheet metal stainless sheet metal painted sheet metal

The classification according to EN 13501-3+A1*):

El 60 (ve ho i↔o) S El 90 (ve ho i⇔o) S El 120 (ve i↔o) S

Assessed product performance

| Essential characteristics | Requirement clauses in EN 15650 | Findings | Conformity |
|---|------------------------------------|----------|------------|
| Nominal activation conditions/sensitivity: | 4.2.1.2 | - | conforms |
| sensing element load bearing capacity | 4.2.1.2.2 | - | conforms |
| sensing element response temperature | 4.2.1.2.3 | _ | conforms |
| Response delay (response time): closure time | 4.2.1.3 | _ | conforms |
| Operational reliability: - cycling | 4.3.1, a) | 0 cycles | conforms |
| Fire resistance | | | |
| integrity | 4.1.1, a) | E | conforms |
| insulation | 4.1.1, b) | EI | conforms |
| smoke leakage | 4.1.1, c) | EIS | conforms |
| mechanical stability (under E) | 4.1.1, a) | W. | conforms |
| maintenance of the cross section (under E) | 4.1.1, a) | | conforms |
| Durability of response delay: sensing element response to temperature and load bearing capacity | 4.2.1.2.2 4.2.1.2.3 | - 2 | conforms |
| Durability of operational reliability: open and closing cycle tests | 4.3.3.2 | _ | NPD |

Other characteristics

| Resistance against corrosion | 4.2.2 Annex B | Salt spray exposure test (EN 60068-2-52) – no corrosion occurred | conforms | |
|------------------------------|------------------|--|----------|--|
|------------------------------|------------------|--|----------|--|

Detailed technical parameters and conditions of the final classification according to EN 13501-3+A1 are stated in the Assessment Report of Performance of the Construction product No. P-1391-CPR-2020/0129 of 20th August 2020.



MANDÍK a.s.

Dobříšská 550, 267 24 Hostomice, CZ

1391 - CPR - 2020/0129/O1

EN 15650

Fire damper

type/model: Fire damper CFDM and CFDM-V

Classification

El 60 (ve ho i↔o) S El 90 (ve ho i↔o) S

El 120 (ve i↔o) S

Jaroslav Dufek

Managing Director PAVUS, a.s. Notified Body No.1391