


# Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Dr. Thomas-Benjamin Seiler

Träger: Verein des Hygiene-Instituts des Ruhrgebiets e.V.



Hygiene-Institut · PO Box 10 12 55 · DE 45812 Gelsenkirchen · Germany

Address:

Rotthauer Str. 21, DE 45879 Gelsenkirchen

Switchboard +49 (0)209 9242-0

Telefax +49 (0)209 9242-222

Internet [www.hyg.de](http://www.hyg.de)

Our reference: W-413542e-26-Zd

Contact person: B. Zeidler

Gelsenkirchen, 02.04.2026

## Certificate

### hygiene-conformity check to the design requirements of selected regulations

Test institute: Hygiene Institut des Ruhrgebiets  
Institut für Umwelthygiene und Toxikologie  
Rotthauer Straße 21  
45879 Gelsenkirchen

Test object: "M, P, T, M+, P+, T+"

Manufacturer: Mandik, a.s.  
Dibrisska 550  
267 24 Hostomice  
Czech Republic



Basis of the examination: ✓ VDI 6022, sheet 1 (01/2018) ✓ DIN 1946, part 4 (09/2018)  
✓ VDI 3803, sheet 1 (05/2020) ✓ ÖNORM H 6020 (03/2024)  
✓ ÖNORM H 6021 (01/2023) ✓ SWKI VA104-01 (01/2019)  
✓ SWKI VA105-01 (08/2015)

Validity period: 5 years 04/2026 – 04/2031

Test report: W-413542-26-Zd

In conclusion it can be stated that the examined air handling units "M, P, T, M+, P+, T+", as specified in the test report W-413542-26-Zd, is in compliance with the above mentioned regulations.

(B. Zeidler)

Clerk of the Department hygienic building technology

(J. Rolle B. Eng.)

clerk of the Department hygienic building technology

issued 02.04.2026, Gelsenkirchen

Within the framework of the conformity check the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the conformity check does not include a toxicological or sensory testing of the introduced materials.

Legal Entity: Verein des Hygiene-Instituts des Ruhrgebiets e.V., Register: VR 519 Local Court Gelsenkirchen (Germany); VAT ID: DE125018356

Directorate: Prof. Dr. Jürgen Kretschmann (Head), Andrea Henze, Joachim Löchte, Dr. Frank Obenaus, Dr. Thomas-Benjamin Seiler (Executive Member), Dr. Dirk Waider