

1.	Unique identification code of the product-type	<b>FDMB</b>
2.	Products	Fire dampers
	Intended use	To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.
	Technical documentation – product information, instruction for installation and maintenance, safety information	Technical specifications <a href="#">TPM 075/09</a>
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 <a href="mailto:mandik@mandik.cz">mandik@mandik.cz</a> , <a href="http://www.mandik.com">www.mandik.com</a>
5.	System of AVCP	System 1
6.	Harmonised standard	EN 15650:2010
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2024/0116 Assessment Report of Performance of Construction Product No. P-1391-CPR-2024/0116

7a. Declared performances – fire resistance classification		
Essential characteristics in accordance with EN 15650:2010, art. 4.1.1		
Fire separating construction, location of the damper	Installation type, installation system	Performance – class of fire resistance
Solid wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum <sup>1)</sup>	EI 120 ( $v_e \leftrightarrow o$ ) S <sup>2)</sup>
	Battery – mortar or gypsum <sup>1)</sup>	EI 90 ( $v_e \leftrightarrow o$ ) S
	Installation next to wall – mortar or gypsum and mineral wool <sup>1)</sup>	
	Mineral wool with fire resistant coating and calcium silicate boards <sup>1)</sup>	
	Installation frame E1, E2, E4 <sup>1)</sup>	
	Ablative coated batt <sup>1)</sup>	
	Fire protection foam with stucco plaster <sup>1)</sup>	EI 60 ( $v_e \leftrightarrow o$ ) S
Solid wall construction – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with Rockwool Conlit Ductrock EIS 120 th. 60 mm + mineral wool with fire-resistant coating and board <sup>1)</sup>	EI 120 ( $v_e \leftrightarrow o$ ) S
	Insulation of the duct with Rockwool Conlit Ductrock EIS 90 th. 60 mm + mineral wool with fire-resistant coating and board <sup>1)</sup>	EI 90 ( $v_e \leftrightarrow o$ ) S
	Insulation of the duct with calcium silicate boards – installation frame E6 <sup>1)</sup>	

(table continues)

1] Refer to [Technical documentation](#) for the details of the installation type / installation system.

2] Tested at increased underpressure of 500 Pa.

(continuation of the table)

<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance</i>
Solid wall construction – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with mineral wool ISOVER ULTIMATE PROTECT th.120 mm (2x60) + Ablative coated batt <sup>1]</sup>	EI 90 ( $v_e \leftrightarrow o$ ) S
	Insulation of the duct with mineral wool ISOVER ULTIMATE PROTECT th.80 mm + Ablative coated batt <sup>1]</sup>	EI 60 ( $v_e \leftrightarrow o$ ) S
Gypsum plasterboard wall construction – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum <sup>1]</sup>	EI 120 ( $v_e \leftrightarrow o$ ) S <sup>2]</sup>
	Battery – mortar or gypsum <sup>1]</sup>	EI 90 ( $v_e \leftrightarrow o$ ) S
	Installation next to wall – mortar or gypsum and mineral wool <sup>1]</sup>	
	Mineral wool with fire resistant coating and calcium silicate boards <sup>1]</sup>	EI 60 ( $v_e \leftrightarrow o$ ) S with wall EI 60 EI 90 ( $v_e \leftrightarrow o$ ) S with wall EI 90
	Installation frame E1, E3 <sup>1]</sup>	
	Ablative coated batt <sup>1]</sup>	EI 60 ( $v_e \leftrightarrow o$ ) S with wall EI 60 EI 90 ( $v_e \leftrightarrow o$ ) S with wall EI 90
	Flexible ceiling – installation frame E5 <sup>1]</sup>	
	Fire protection foam with stucco plaster <sup>1]</sup>	EI 60 ( $v_e \leftrightarrow o$ ) S
Gypsum plasterboard wall construction – damper in the wall – 75 mm min. wall thickness	Ablative coated batt <sup>1]</sup>	EI 30 ( $v_e \leftrightarrow o$ ) S EI 45 ( $v_e \leftrightarrow o$ ) S
Gypsum plasterboard wall construction – damper remote from the wall – 100 mm min. wall thickness	Insulation of the duct with Rockwool Conlit Ductrock EIS 120 th. 60 mm + mineral wool with fire-resistant coating and board <sup>1]</sup>	EI 120 ( $v_e \leftrightarrow o$ ) S
	Insulation of the duct with Rockwool Conlit Ductrock EIS 90 th. 60 mm + mineral wool with fire-resistant coating and board <sup>1]</sup>	EI 90 ( $v_e \leftrightarrow o$ ) S
	Insulation of the duct with mineral wool ISOVER ULTIMATE PROTECT th.120 mm (2x60) + Ablative coated batt <sup>1]</sup>	
	Insulation of the duct with mineral wool ISOVER ULTIMATE PROTECT th.80 mm + Ablative coated batt <sup>1]</sup>	EI 60 ( $v_e \leftrightarrow o$ ) S
CLT wooden wall – damper in the wall – 100 mm min. wall thickness	Mortar or gypsum <sup>1]</sup>	EI 90 ( $v_e \leftrightarrow o$ ) S
	Ablative coated batt <sup>1]</sup>	
Solid ceiling construction – damper in the ceiling – 150 mm min. ceiling thickness	Mortar or gypsum <sup>1]</sup>	EI 120 ( $h_o \leftrightarrow o$ ) S <sup>2]</sup>
	Battery – mortar or gypsum <sup>1]</sup>	EI 90 ( $h_o \leftrightarrow o$ ) S
	Mineral wool with fire resistant coating and boards <sup>1]</sup>	
	Installation frame E1, E2, E4 <sup>1]</sup>	
	Ablative coated batt <sup>1]</sup>	

(table continues)

1] Refer to [Technical documentation](#) for the details of the installation type / installation system.

2] Tested at increased underpressure of 500 Pa.

(continuation of the table)

<i>Fire separating construction, location of the damper</i>	<i>Installation type, installation system</i>	<i>Performance – class of fire resistance</i>
Solid ceiling construction – damper remote from the ceiling – 150 mm min. ceiling thickness	Insulation of the duct with Rockwool Conlit Ductrock EIS 120 th. 60 mm + mortar or gypsum <sup>1]</sup>	EI 120 ( $h_o$ $i \leftrightarrow o$ ) S
	Insulation of the duct with Rockwool Conlit Ductrock EIS 90 th. 60 mm + mortar or gypsum <sup>1]</sup>	EI 90 ( $h_o$ $i \leftrightarrow o$ ) S
	Concrete <sup>1]</sup>	
	Insulation of the duct with cement lime plates – installation frame E6 <sup>1]</sup>	
CLT wooden ceiling – damper in the ceiling – 140 mm min. ceiling thickness	Mortar or gypsum <sup>1]</sup>	EI 90 ( $h_o$ $i \leftrightarrow o$ ) S
	Ablative coated batt <sup>1]</sup>	
Shaft construction of EI 90 fire resistance class	Ablative coated batt <sup>1]</sup>	EI 90 ( $v_e$ $i \leftrightarrow o$ ) S
Shaft construction of EI 60 fire resistance class	Ablative coated batt <sup>1]</sup>	EI 60 ( $v_e$ $i \leftrightarrow o$ ) S

1] Refer to [Technical documentation](#) for the details of the installation type / installation system.

7b. Declared performances – essential characteristics		
Essential characteristics	Requirements (provisions of the harmonised standard EN 15650:2010)	Performance (lever or class) / Compliance with the requirements
Nominal activation conditions/sensitivity: – sensing element load bearing capacity	4.2.1.2 4.2.1.2.2	Conforms Conforms
– sensing element response temperature	4.2.1.2.3	Conforms
Response delay (response time): – closure time	4.2.1.3	Conforms
Operational reliability: – cycling	4.3.1, a)	50 cycles – conforms
Durability of response delay: – sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms
Durability of operational reliability: – opening and closing cycle tests	4.3.3.2	Dampers with mechanisms MANDÍK M: NPD MANDÍK MODULAR: C <sub>300</sub> BELIMO, SCHISCHEK: C <sub>10.000</sub> GRUNER: C <sub>MOD</sub>

The performance of the product identified above is in conformity with the set of declared performance/s.  
 This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 2025-01-02



Jan Mičan  
 CEO, Ppa  
 MANDÍK, a.s.

Declared performances – other characteristics		
Characteristics	Technical standard	Performance (lever or class) / Compliance with the requirements
Resistance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms
Application with no ducting	EN 1366-2:2015 art. 6.2.7	Conforms
Damper blade tightness	EN 1751:2024	Class 2
Damper casing tightness	EN 1751:2024	For A < 160 mm or B < 160 mm class ATC 4 (old marking "B"), for other sizes class ATC 3 (old marking "C").

#### Additional provisions for use of the product in Austria

The product-type products meet also all requirements of ÖNORM H 6025 standard, cf. Certificate No. P-1391-CPR-2024/0116.